



महाराष्ट्र राज्य सार्वजनिक आरोग्य सेवा "अ"

जिल्हा सार्वजनिक आरोग्य प्रयोगशाळा जालना

नर्सिंग ट्रेनिंग सेंटर बिल्डींग सामान्य रुग्णालय परिसर जालना ४३१२०३

दुरध्वनी क्र.०२४८२-२९७५११ ईमेल:- dphljn@gmail.com



पाणी नमुन्यांचा सुक्ष्मजीवीय अहवाल (As per BIS Specification 10500 : 2012)

पाठविणा-याचे नाव व पत्ता		आदर्श स्कूल, पारनेर ता. मंगड			
पाठविणा-याचे पत्र क्रमांक व दिनांक		4109/2026			
प्रयोगशाळा संदर्भ क्रमांक		11345			
नमुना घेतल्याचा दिनांक		4109/2026			
नमुना पोहचल्याचा दिनांक		—			
नमुना तपासणीचा दिनांक		—			
अ.क्र.	पाणी नमुन्याचे विवरण	प्रती १०० मि.ली.नमुन्यातील संभाव्य सुक्ष्मजंतूची संख्या			
		कोलीफॉर्म	थर्मोटॉलरंट कोलीफॉर्म	ई.कोलाय	अभिप्राय
	उपरोक्त पत्राकडून प्राप्त पाणी नमुने क्र ① R10 प्राप्ती क्र :- 9040540 २५०० :- 3401- 1६ :- 419/2026	0	—	—	पिण्यास योग्य

अभिप्राय :- पिण्यास अयोग्य पाण्यावर योग्य प्रमाणात क्लोरीनची प्रक्रिया केल्यानंतर व सुक्ष्मजीवीय पुनर्तपासणी नंतर पिण्यास योग्य असल्याची खात्री झाल्यावर ते पाणी पिण्यासाठी वापरता येईल.

टिप :- वरील पाणी नमुने या प्रयोगशाळेने गोळा केलेले नाहीत. तसेच तपासणीकरिता प्राप्त झालेले पाणी नमुने प्रातिनिधीक स्वरूपाचे आहेत असे गृहित धरण्यात येत आहे.

अहवाल क्रमांक :- 3083 दिनांक :- 10/9/2026

प्रत १. जिल्हा आरोग्य अधिकारी, जिल्हा परिषद जालना
सादर २. जिल्हा शल्यचिकित्सक, जिल्हा रुग्णालय जालना
इमेल ३. मुख्याधिकारी, नगर परिषद/नगर पंचायत.....
व्दारे ४. गटविकास अधिकारी, पं.स.तालुका.....
५. तालुका आरोग्य अधिकारी, पं.स. तालुका.....

Forman
कनिष्ठ वैज्ञानिक अधिकारी
जिल्हा सार्वजनिक आरोग्य प्रयोगशाळा जालना



GOVERNMENT OF MAHARASHTRA

Maharashtra State Public Health Services

District Public Health Laboratory, Jalna (M.S.)

E-mail - dphljalna@gmail.com

Phone/ Fax : (02482) 225294

No.DPHL/Jalna/Water/ 2711

Dtd. 24 /08/2026

Report Of Sample : R.O Sent by: Principal Adarsh School ,Parner Tq.Ambad,Dist .Jalna

Date of Collection : 17 /08/2026 Date of Receipt: 17/08/2026 Date of Exami: 17/08/2026 onwards
With reference to letter No.802 /2026

Lab.Ref.No 59

(Analytical Result in mg/litre (except pH and Turbidity)

S r. N	Tests	R.O <i>Water</i>	BIS Specification 10500:2012	
			Desirable Limits	Permissible Limits
1.	Physical Appearance	Clear	---	---
2	Colour	Colourless	Colourless	Colourless
3	Odour	Odourless	Agreeable	Agreeable
4	Turbidity (as N.T.U.)	0.10	1.0	5.0
5	pH	6.5	6.5 to 8.5	No relaxation
6	Chloride (as Cl)	17	250	1000
7	Nitrates (as NO ₃)	1	45	No relaxation
8	Total Hardness	36	200	600
9	Alkalinity (as CaCO ₃)	30	200	600
10	Total Dissolved Solids	88	500	2000
11	Iron (as Fe)	0.01	0.3	1.0
12	Fluoride (as F)	0.2	1.0	1.5

Remark :- Above submitted Sample is chemically fit for drinking purpose.

Note : This laboratory has not collected sample (s).The results of analysis contained in this report relate only to the sample(s) submitted by party.

Forwarded with compliments to :-

Principal Adarsh School ,Parner Tq.Ambad,Dist .Jalna

Fees:600 / , Receipt No:9040473

Forman
Junior Scientific Officer
Dist.Public Health Laboratory Jalna



Maharashtra State Public Health Service "A"

District Public Health Laboratory, Jalna


Nurses Training Centre Building, General Hospital Campus, Jalna – 431203
Telephone No.: 02482-297511 Email: dphljln@gmail.com

Microbiological Report of Water Samples (As per BIS Specification 10500 : 2012)					
Name and Address of the Sender		Adarsh School, Parner, Tal. Ambad			
Sender's Letter No. and Date		4/09/2026			
Laboratory Reference No.		11345			
Date of Sample Collection		4/09/2026			
Date of Receipt of Sample		—			
Date of Testing of Sample		—			
Sr. No.	Description of Water Sample	Probable number of micro-organisms per 100 ml of sample			
		Coliforms	Thermotolerant Coliforms	E. coli	Remarks
	Water received as per the above letter, Sample No. 1 R10 Receipt No.: 9040540 Amount: Rs. 340/- Date: 4/9/2026	0	—	—	Fit for drinking (Potable)
Remarks:- Water found unfit for drinking may be used for drinking only after proper chlorination and after it is confirmed to be fit for drinking on microbiological re-examination.					
Note:- The above water samples have not been collected by this laboratory. Further, the water samples received for testing are assumed to be representative.					
Report No.: 3083		Date:- 10/9/2026			

Copy submitted by email to:

1. District Health Officer, Zilla Parishad, Jalna.
2. District Civil Surgeon, District Hospital, Jalna.
3. Chief Officer, Municipal Council / Nagar Panchayat
4. Block Development Officer, Panchayat Samiti, Taluka
5. Taluka Health Officer, Panchayat Samiti, Taluka

S D
Junior Scientific Officer
District Public Health Laboratory,
Jalna



BEFORE ME
LAXMAN A. GAIKAR
ADVOCATE NOTARY GOVT. OF INDIA
AREA-AMBAD, DIST-JALNA (MH)
MOB No. 9421188307 REG NO 30628